

Declaration of Performance No. 10-5151-360-200 REV 01

Declaration of Performance according to the Construction Products Regulation EU No. 305/2011

1. Unique identification code of the product type	Model(s): KAL455,KAL455-18, KAL455E,KAL455E-18 Brand(s): Kilsen
2. Intended use/es	Fire detection and fire alarm systems Part 11: Manual call points
3. Manufacturer	KAC Alarm Company Ltd. KAC House, Thornhill Road,North Moons Moat,Redditch,Worcestershire, B98 9ND,UK
4. Authorized representative	UTC Fire & Security B.V., Kelvinstraat 7, NL-6003 DH Weert, The Netherlands
5. System or systems of AVCP	System 1
6a. Harmonised standard/s:	EN 54-11:2001 +A1:2005
Notified body/ies:	0832 BRE
6b. European Assessment Document: European Technical Assessment: Technical Assessment Body: Notified body/ies:	Not applicable

7. Declared performances:
Control and Indicating Equipment EN54-11

Essential characteristics	Performance	Harmonized technical specification
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	PASS	EN 54-11:2001 + A1:2005
Operational reliability	--	--
Durability of operational reliability and response delay; temperature resistance	PASS	EN 54-11:2001 + A1:2005
Durability of operational reliability, Vibration resistance	PASS	EN 54-11:2001 + A1:2005
Durability of operational reliability, Humidity resistance	--	--
Durability of operational reliability, Electrical stability	PASS	EN 54-11:2001 + A1:2005
Durability of operational reliability, Corrosion resistance	PASS	EN 54-11:2001 + A1:2005


8. Appropriate Technical Documentation and/or Specific Technical Documentation:


The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed For and on behalf of: UTC Fire & Security

Name: Jose Maria Mendez Segui .
Function: Technology Manager , EMEA

Place: Verge de Guadalupe 3, Esplugues de Llobregat
08950, Barcelona, Spain


27 March 2017

Regulation (EU) No. 305/2011 CPR Supplementary CE marking information

Identification of the Certification Body:0832
Manufacturer: KAC Alarm Company Ltd. KAC House, Thornhill Road,North Moons Moat,Redditch,Worcestershire, B98 9ND,UK
Last two digits of year CE mark was first placed:08
Declaration of Performance (DoP) Number: 10-5151-360-200 REV 02
EN 54-11:2001+ A1:2005
Unique identification of product type: See the product label for the product documentation part number and revision.
Intended use: See DoP point 2.
Essential characteristics: See DoP point7.

EN: Get this document in your language from: / BG: Вземете този документ на български език от / CZ: Získat tento dokument ve Vašem jazyce od: / DA: Få dette dokument på dit sprog fra: / NL: Krijg dit document in uw taal van: / ET: Dokumendi eestikeelse versiooni leiata siit: / ES: Obtenga este documento en su idioma de: / FI: Hanki tämä asiakirja kielelläsi: / FR: Obtenez ce document dans votre langue de: / DE: Sie erhalte das Dokument in Ihrer Sprache von: / EL: Μπορείτε να παραλάβετε το έγγραφο στη γλώσσα σας από: / HU: A dokumentum megvásárolható a kívánt nyelven: / IT: Ottieni questo documento nella tua lingua da: / LV: Iegūstiet šo dokumentu savā valodā no: / LT: Gauti šį dokumentą jūsų kalba iš: / PL: Pobierz ten dokument w swoim języku z: / PT: Obtenha este documento no seu idioma a partir: / RO: Puteti obtine acest document in limba dumneavoastra de la: / SK: Získať tento dokument vo Vašom jazyku od: / SL: Spravi ta dokument v vašem jeziku od: / SV: Få detta dokument på ditt språk från:

<http://www.utcssecurityproducts.eu/dop/>

DoP.Requests@fs.utc.com

© 2017 UTC Fire & Security. All rights reserved