

Sede legale ed operativa: Via Settembrini, 34 - 20020 Lainate (MI) - ITALIA

Tel. 02.58077.1 (8 linee r. a.) - Fax 02.58077.277 - E-mail: info@paso.it - <http://www.paso.it> | C.F. - P. IVA n° 00930730155

Trib. Milano n° 152455/3751/5 - C.C.I.A. numero REA: MI- 853.303 | Registro A.E.E.: IT0803000004137 | Capitale Sociale € 1.170.000 I.V.

Società soggetta a direzione e coordinamento di FBT Elettronica S.p.a.

DECLARATION OF PERFORMANCE

n° DoP_C36/6-2EN_039/2016

- | | |
|--|---|
| 1. Unique product identification code: | Fire detection and fire alarm system.
Components of voice alarm systems
Loudspeakers. |
| 2. Serial number, type, lot: | C36/6-2EN
Wall mounting speaker 3+3W ABS UL94-V0
Unique serial number on each product and registered in
company network system |
| 3. Using the product as intended by the manufacturer: | Active protection against fire according to EN 54-24:2008.
TYPE A |
| 4. Identification of the manufacturer: | PASO SpA
Via Settembrini, 34 20020 Lainate (MI)
ITALY |
| 5. Authorized representative: | NN |
| 6. System for assessment and monitoring of performance reliability: | System 1 |
| 7. Declaration on the performance concerning a construction product falls within the scope of harmonized standards. | |
| Notified body: | MTIC INTERCERT SRL
Via Moscova, 11 20017 Rho (MI)
ITALY |
| Identification number: | 0068 |
| It carried out the initial evaluation of the product, the initial inspection of the production and production control based on the system 1 releasing: | Certificate of Conformity CE
nr. 0068-CPR-039/2016 |
| 8. Declaration of performance concerning a construction product issued pursuant to a european technical verification: | NN |

9. Declared performance.

Reference to the harmonized technical standard
EN 54-24:2008

Performance in case of fire	PASS	Par. 4.2, 5.2, 5.3, 5.4, 5.5
Operational reliability	PASS	Par. 4.3, 4.4, 4.5, 5.6, 5.18
Operational reliability Thermal resistance	PASS	Par. 5.7, 5.8, 5.9
Operational reliability Air humidity resistance	PASS	Par. 5.10, 5.11, 5.12
Operational reliability Corrosion resistance	PASS	Par. 5.13
Operational resistance Shock and vibration resistance	PASS	Par. 5.14, 5.15, 5.16, 5.17

10. The performance of the product referred to in points 1,2 are in accordance with the declared benefits referred to on paragraph 9.

Belloni Roberto / Quality Manager

Name and Company Position



Lainate, 20/06/2018

Place and Issue Date

FIRMA