

**Sede legale ed operativa: Via Settembrini, 34 - 20020 Lainate (MI) - ITALIA**

Tel. 02.58077.1 (8 linee r. a.) - Fax 02.58077.277 - E-mail: [info@paso.it](mailto:info@paso.it) - <http://www.paso.it> | C.F. - P. IVA n° 00930730155

Trib. Milano n° 152455/3751/5 - C.C.I.A. numero REA: MI- 853.303 | Registro A.E.E.: IT0803000004137 | Capitale Sociale € 1.170.000 I.V.

Società soggetta a direzione e coordinamento di FBT Elettronica S.p.a.

**DECLARATION OF PERFORMANCE**  
**n° DoP\_C440-EN\_039/2016**

- |  |  |
|--|--|
| 1. Unique product identification code:   | <b>Fire detection and fire alarm system.<br/>Components of voice alarm systems<br/>Loudspeakers.</b>                                 |
| 2. Serial number, type, lot:   | <b>C440-EN<br/>Sound Column 40W metal case<br/>Unique serial number on each product and registered in<br/>company network system</b> |
| 3. Using the product as intended by the manufacturer:  | <b>Active protection against fire according to EN 54-24:2008.<br/>TYPE A</b>   |
| 4. Identification of the manufacturer:   | <b>PASO SpA<br/>Via Settembrini, 34 20020 Lainate (MI)<br/>ITALY</b>   |
| 5. Authorized representative:  | <b>NN</b>  |
| 6. System for assessment and monitoring of performance reliability:  | <b>System 1</b>  |
| 7. Declaration on the performance concerning a construction product falls within the scope of harmonized standards.                                    |  |
| Notified body:   | <b>MTIC INTERCERT SRL<br/>Via Moscova, 11 20017 Rho (MI)<br/>ITALY</b>   |
| Identification number:   | <b>0068</b>  |
| It carried out the initial evaluation of the product, the initial inspection of the production and production control based on the system 1 releasing: | <b>Certificate of Conformity CE<br/>nr. 0068-CPR-039/2016</b>  |
| 8. Declaration of performance concerning a construction product issued pursuant to a european technical verification:                                  | <b>NN</b>  |

9. Declared performance.

Reference to the harmonized technical standard  
**EN 54-24:2008**

Performance in case of fire	<b>PASS</b>	Par. 4.2, 5.2, 5.3, 5.4, 5.5
Operational reliability	<b>PASS</b>	Par. 4.3, 4.4, 4.5, 5.6, 5.18
Operational reliability Thermal resistance	<b>PASS</b>	Par. 5.7, 5.8, 5.9
Operational reliability Air humidity resistance	<b>PASS</b>	Par. 5.10, 5.11, 5.12
Operational reliability Corrosion resistance	<b>PASS</b>	Par. 5.13
Operational resistance Shock and vibration resistance	<b>PASS</b>	Par. 5.14, 5.15, 5.16, 5.17

10. The performance of the product referred to in points 1,2 are in accordance with the declared benefits referred to on paragraph 9.

Belloni Roberto / Quality Manager

\_\_\_\_\_  
Name and Company Position



Lainate, 20/06/2018

\_\_\_\_\_  
Place and Issue Date

FIRMA