

Attending to this matter, name, telephone  
HCI/T Karl-Ove Andersson (+46 70 586 9478)

Date  
2017-05-22

Document no  
174 53-TEL 310 2023

## Declaration of performance

We, the undersigned, on behalf of Hexatronic Cables & Interconnect Systems AB, hereby declare that the product listed below conform to the relevant harmonized standards, mentioned herein.

Type of product: Signal cable  
Product name/model: ELAQBY-S nn x2x0.6  
Product number: \*/TEL3102023/\*  
\*Prefix "1/" red jacket, without prefix white jacket  
\*Suffix 1-2 pos: No. of conductors "nn"  
\*Suffix 3 pos: Delivery length, B=100m, T=500m  
\*Suffix 4 pos: Custom marked, A first customer, B second,,,  
Intended use: Signal cable for indoor and outdoor installations, according to SS 424 1652 and SS 424 1438

## Harmonized Standards

RoHS, Restriction of Hazardous Substances 2011/65/EU  
CPR, Construction Products Regulation, EN 50575: 2014 + A1:2016  
CE-marking, EN 50575


## Declared Performance

Reaction to fire ***D<sub>ca</sub> -s2, d2, a1***

## Reports

174 24-TEL3102023 Fire test report

Hudiksvall 2017-05-22



Karl-Ove Andersson  
Product Manager

---

### Hexatronic Cables & Interconnect System AB

Office address  
Kabelvägen 1  
824 82 Hudiksvall  
SWEDEN

Telephone  
+46 10 453 02 00

VAT No: SE556514911801  
Reg. No: 556514-9118