

# STATEMENT FOR MICRO-PRODUCTION CONNECTION

The following micro-production facilities are undersigned to connect to existing orders.

## Applicant:

Name:

Address:

Telephone:

## Installer:

Name:

Address:

Telephone:

E-mail:

## Installation Data:

Power Type: ☒ Solar ☐ Wind ☐ Water ☐ Bioindustries

Facility Model: SG33CX

Capacity: 33kVA/kW

Efficiency: Max. 98.3%

Max. AC current: 55.2A

Type-Examination: ☒ Yes ☐ No

Protective Parameters:

Power Protection Settings (found in the inverter typ-testing-protocol)		Set value		Recommended value	
		Time	Level	Time	Level
Over voltage (step 2)		0,1 s	255,3 V	60 s	255,3 V
Over voltage (step 1)		0,1 s	264,5 V	0,2 s	264,5 V
Under voltage		0,1 s	195,5 V	0,2 s	195,5 V
Overfrequency		0,1 s	52 Hz	0,5	51
Underfrequency		0,1 s	47 Hz	0,5	47
Protection against unwanted island operation		NA		0,15 s	
Power quality values		Value	Recommended limit		
Flicker values max 16 A	P <sub>st</sub>	NA	0,35		Flicker calculated according to EN 61000-3-3
	P <sub>lt</sub>	NA	0,25		
Flicker values > 16 A	P <sub>st</sub>	0,29	0,35		Flicker calculated according to: <input type="checkbox"/> EN 61000-3-3 <input type="checkbox"/> EN 61000-3-11
	P <sub>lt</sub>	0,28	0,25		

## Frequency Response Settings

Items	Yes/No	Reference
Can the system remain connected within the following frequency range:		EIFS 2018:2 3rd chptr §1
At least 30 minutes within the frequency range 47.5 - 48.5 Hz?	Y	
At least 30 minutes within the frequency range 48.5 - 49.0 Hz?	Y	
Unlimited in frequency range 49.0 - 51.0 Hz?	Y	
At least 30 minutes within the frequency range 51.0 - 51.5 Hz?	Y	
Does the facility meet the requirement to remain connected to the network and operate at frequency change rates up to 2.0 Hz /s? <sup>1</sup>	Y	EIFS 2018:2 3rd chptr §2
Can the plant reduce its active power output when frequency exceeds 50.5 Hz?	Y	EIFS 2018:2 3rd chptr §3
Does the plant meet the statistic factor <sup>2</sup> requirement of 8%?	Y	EIFS 2018:2 3rd chptr §4
Reduced output power from the system by maximum 3.0 percent per Hz at frequencies lower than 49.0 Hz?	Y	EIFS 2018:2 3rd chptr §7
Automatic reconnection of the system takes place only within frequency range 47.5 - 50.1 Hz	Y	EIFS 2018:2 3rd chptr §8
If yes to the above, certify that connection is made first when the network frequency has been within this range continuous for at least 3 minutes?	Y	EIFS 2018:2 3rd chptr §8
The plant meets the requirement for an increase in output active power at automatic connection according to:		EIFS 2018:2 3rd chptr §9
<49.9 Hz - Increased rate of output active power not limited	Y	
49.9–50.1 Hz - Increased rate of output active power is maximum 10 percent of rated output per minute	Y	
> 50.1 Hz - Increase of output active power does not occur	Y	
	<b>Value</b>	
Enter the lowest active power output (in kW) that the plant can be controlled down to over frequency	3	EIFS 2018:2 3rd chptr §5

<sup>1</sup> The value of the frequency change rate should be measured at the connection point and calculated over a period of 0.5 s.

<sup>2</sup> The statistic factor is the ratio between a frequency change and the change in output power expressed as a percentage. The frequency change is expressed as a ratio between current frequency and nominal frequency. The output power is expressed as a ratio between rated power and output power at over-frequency on the grid. At control of output power due to over-frequency, the static factor is calculated based on the installed power of the system. According to section 6 of EIFS 2018: 2.

It is hereby certified that the above information is correct:

Signature

Printed name

City

Date